

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1209:202

Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models WFD20EXP, -25EXP, -30EXP, -30-2EXP, -35EXP, -40EXP, -50EXP, -60EXP, and -80EXP paddle-type wet pipe sprinkler, waterflow indicators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	<u>Model</u>	<u>Size</u>	<u>Working Pressure</u>
	WFD20EXP	2"	450 psig
	WFD25EXP	2-1/2"	450 psig
	WFD30EXP	3"	450 psig
	WFD35EXP	3-1/2"	450 psig
	WFD40 EXP	4"	450 psig
	WFD50EXP	5"	450 psig
	WFD60 EXP	6"	450 psig
	WFD80 EXP	8"	450 psig
	WFD30-2EXP	3"	450 psig

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as waterflow indicators for use with wet pipe fire sprinkler systems. Suitable for use in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager